

RANGE HOOD(S) APPLICATION

Merrimack Fire Rescue Office of the Fire Marshal

432 DW Highway Merrimack NH 03054 Office: 603-424-3690 fax: 603-424-0603

In accordance with the Merrimack Department Fire Rescue, NO work will begin prior to the issuance of proper permits and documentation and/or approvals by the Merrimack Department of Fire Rescue, Office of the Fire Marshal.

| All fields shall be comple | eted. If not applicable, | please mark with N/A | Date: | |
|--|---|-----------------------------|----------------|------|
| | SIT | E INFORMATION | | |
| Building / Site Name: | | | | |
| Site Address: Number: | Street Name: | | | |
| Will the area of this work b | e tenant occupied Yes [| ☐ NO ☐ (If yes fill in info | rmation below) | |
| | OCCUPANT | / TENANT INFORM | ATION | |
| Name: | | Business Name: | | |
| Address: | | City | State | Zip: |
| Phone#: | | | | |
| Contact Name: | | Cell Phone: | | |
| Name: | | City | State | Zip: |
| Phone#: | | | | |
| | | Expiration Date: | | |
| | | Expiration: | | |
| DOES THE SCOPE OF TI DOES THIS WORK INVO IS THIS A REPLACEMEN PROJECT NARRATIV (Including specific scope a | LVE MORE THAN ONE T OF AN EXISTING SYS | SUPPRESSION SYSTE | | |
| | | | | |

TYPE OF SYSTEM:

| (Check the one most applicable) | |
|---|------------------------|
| □ Dry Chemical □ Wet Chemical □ Wet Chemical & Sprinklered □ Deep Fat Fryer (Pre-engineered/Self Contained) □ Sprinklered Rangehood | |
| Manufacturer: | Model: |
| Quantity of Extinguishing Agent: | Name of Agent: |
| Multiple Hood Suppression Systems: Yes \square or No \square | If yes, how many? |
| Number of Nozzles and Type: | |
| Number of Fusible Links:Link Tem | perature(s): |
| INDICATE THE HAZARD AND APPLIANCES TO BE | PROTECTED: |
| Appliance(s) Protected Appliance Fuel Source | |
| | |
| | Gas Electric Other |
| | Gas 🗌 Electric 🗌 Other |
| | Gas Electric Other |
| | |

Note:

(check the one most applicable)

The issuance of a permit based upon plans specifications, data and other reports shall not prevent the Merrimack NH Department of Fire Rescue, Office of the Fire Marshal from thereafter requiring correction of deficiencies. Any deficiencies found during field inspection, testing, or Fire Company Surveys shall also be corrected.

The completed installation shall pass a visual inspection and complete operating test witnessed by a representative of the Merrimack Office of the Fire Marshal. Please call for your Inspection at least 24 hours in advance to schedule inspections or tests.

The Fire Suppression System is required to be connected to Building Fire Alarm System

In accordance with the Merrimack NH Fire Code, no permit-required work will begin prior to the issuance of proper permits and / or approvals by the Merrimack Department of Fire Rescue, Office of the Fire Marshal.

Submittal of plans and payment of fees does not imply Permission or permit by the Merrimack Department of Fire Rescue, Office of the Fire Marshal for project design or commencement of work.

The system design shall comply with UL300 Fire Extinguishing Systems for Protection of Restaurant Cooking Areas, NFPA 17A Wet Chemical Extinguisher Systems and NFPA 96 Installations of Equipment for the Removal of Smoke and Grease Laden Vapors from Commercial Cooking Equipment and local or state codes and standards.

APPROVED PLANS AND A COPY OF THE PERMIT MUST BE KEPT ON SITE DURING CONSTRUCTION.

THE FOLLOWING ARE INCLUDED AND REQUIRED FOR SUBMITTAL:

Two sets of Drawings (Fire Dept retains one copy and one copy will be stamped and returned) Equipment Cut-Sheets (Copies of catalog pages showing new equipment)