



TOWN OF MERRIMACK, NEW HAMPSHIRE

FINANCE DEPARTMENT
6 Baboosic Lake Road
Merrimack, NH 03054

Tel: 603-424-7075
Fax: 603-424-0516

April 25, 2024

ADDENDUM #2
TO
REQUEST FOR BID
Roof Replacement on Salt Shed

In reference to the Town of Merrimack's request to replace the roof of the Salt Shed Building at the Highway Maintenance Complex, Friday, May 3, 2024 at 2:00PM, *please be advised that the following questions have been answered:*

- 1. *For the ice and water shield, is it around entire perimeter or just the eaves?***
We would like the ice and water shield around the entire perimeter, up to 6' to 8'.
- 2. *Can I provide 2 quotes for different quality shingles?***
Yes, you can provide 2 quotes. We ask that you provide each quote on a separate bid form. You can label them bid #1 and bid #2.
- 3. *Does the ice and water shield need to be granulated?***
You can put in a price for granulated and non-granulated in the exceptions area of the bid form.

Please contact me at kvalluzzi@merrimacknh.gov or (603) 424-7075 if you have any questions pertaining to this addendum or other portions of our bid request.